

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                     | Date Issued and Regional Health Authority                        | Title                                     | PDWA | EBWO | Comments   |
|---|--|---|------|------|--|
| 3 Flags Motorsports Park Well [21936]   | 26-Aug-10<br>No. 4 - Regina Qu'Appelle Regional Health Authority | EBWO - Three Flags Motorsports Park       |      | 1    | Operational: Undetermined source of contamination<br><br>Quality: E.coli detected in drinking water system |
| All Season Service [238]                | 17-Feb-11<br>Prince Albert Parkland Regional Health Authority    | EBWO- All Season Service, Candle Lake, SK |      | 1    | Operational: Does not meet reporting requirements<br><br>Quality: E.coli detected in drinking water system |
| All Seasons Resort Water System [24146] | 14-Jul-11<br>Prairie North Regional Health Authority             | All Seasons Resort - Turtle Lake EBWO     |      | 1    | Operational: Does not meet minimum treatment/design requirements<br><br>Quality:                           |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply   | Date Issued and<br>Regional Health<br>Authority                               | Title   | PDWA | EBWO | Comments   |
|---|---|---|------|------|--|
| Angler Trail Resort Ltd. (Darsana Property) [22007]                     | 11-Jun-09<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Angler Trail Resort Ltd. (Darsana Property) [22007]                                      | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Approved Home of June Falkowski [13887]<br><br>located - SW 14-28-05 W2 | 19-Mar-08<br><br>Sunrise<br>Regional Health<br>Authority                      | PDWA for Approved Home of June Falkowski due to total coliforms, E.coli. & lack of water sampling |      | 1    | Operational: Does not meet monitoring requirements<br><br>Quality: E.coli detected in drinking water system                            |
| Arctic Lodges Ltd. [15000]  | 04-Sep-10<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA - Arctic Lodges Ltd due to detection of total coliforms                                      | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                  | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|--|--|--|------|------|--|
| Athabasca Fishing Lodges - Engler Lake Lodge [15232] | 01-Jul-07<br>Mamawetan Churchill River Regional Health Authority | EBWO for Athabasca Fishing Lodges - Engler Lake due to E.coli        |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Balgonie Shell Well [16976]                          | 09-May-11<br>No. 4 - Regina Qu'Appelle Regional Health Authority | PDWA Balgonie Shell Well due to unsatisfactory sampling requirements | 1    |      | Operational: Does not meet monitoring requirements<br><br>Quality:   |
| Baptiste Lake Lodge [22000]                          | 05-Jun-09<br>Mamawetan Churchill River Regional Health Authority | PDWA for Baptiste Lake Lodge Ltd. due to total coliforms             | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                       | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments  |
|---|--|--|------|------|---|
| Bayside Bed and Breakfast [15494]         | 16-Jun-08<br>Mamawetan Churchill River Regional Health Authority | PDWA - Bayside Bed and Breakfast due to detection of total coliforms | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system  |
| Besnard Lake Campground [15994]           | 29-Aug-11<br>Mamawetan Churchill River Regional Health Authority | Besnard Lake Campground  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Big Sandy Lake Outdoor Adventures [15820] | 26-Jun-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Big Sandy Outdoor Adventures due to E.coli                  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply   | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|---|--|--|------|------|--|
| Bigstone Outfitters [12500]   | 17-Jun-11<br>Mamawetan Churchill River Regional Health Authority | PDWA Issued at Bigstone Outfitters due to detection of total coliforms in drinking water           | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Black Bear Island Lodge [14691]   | 08-Jun-07<br>Mamawetan Churchill River Regional Health Authority | PDWA for Black Bear Island Lodge due to total coliforms  | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Buffalo Hump Community Well [13770]<br><br>RM of Livingston #331 (NW 1/4 7-34-32-W2M) | 18-Mar-09<br>Sunrise Regional Health Authority                   | PDWA for Buffalo Hump Community Well [13770] RM of Livingston #331 (NW 1/4 7-34-32-W2M) -coliforms | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply   | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|---|---|--|------|------|--|
| Burbidge Lake Lodge Ltd.<br>[16531]   | 25-Jun-07<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Burbidge Lake Lodge Ltd. due to E.coli  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Burym Community Well [13739]<br><br>#13739; SW 26-36-3-W2, RM of Clayton #333 | 08-Aug-08<br><br>Sunrise<br>Regional Health<br>Authority                      | PDWA for Burym Community Well #13739; SW 26-36-3-W2, RM of Clayton #333 due to coliform bacteria | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |
| Camp Grizzly [12291]  | 09-Jun-09<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Camp Grizzly due to total coliforms   | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                             | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|---|--|---|------|------|--|
| Canadian Wilderness Sports Camp [20863]         | 20-Jun-08<br>Mamawetan Churchill River Regional Health Authority | PDWA for Canadian Wilderness Sports Camp due to total coliforms                                   | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Cando School Well [15926]                       | 16-Sep-10<br>Heartland Regional Health Authority                 | Cando School and Childcare Centre PDWA  | 1    |      | Operational: Undetermined source of contamination<br><br>Quality: Source water contamination   |
| Canora Beach Resort Public Water Supply [17155] | 04-Sep-09<br>Sunrise Regional Health Authority                   | PDWA for Canora Beach Resort Public Water Supply [17155] due to the presence of coliform bacteria | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply           | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|-------------------------------|--|---|------|------|---|
| Carson South Camp [15203]     | 07-Jun-07<br>Mamawetan Churchill River Regional Health Authority | EBWO for Carson's South Camp due to E.coli  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system   |
| Carson South Camp [15203]     | 21-Jun-08<br>Mamawetan Churchill River Regional Health Authority | EBWO for Carson South Camp due to E.coli  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system   |
| CCJ Well Water Supply [14258] | 12-Jul-11<br>No. 4 - Regina Qu'Appelle Regional Health Authority | EBWO downgraded to PDWA Craven Country Jamboree Well due to coliforms in drinking water | 1    |      | Operational: Treatment unable to cope with significant deterioration in source water quality<br><br>Quality: Unacceptable turbidity or particle counts in treated water |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                              | Date Issued and<br>Regional Health<br>Authority                            | Title  | PDWA | EBWO | Comments   |
|--|--|--|------|------|--|
| Cherrydale Golf and Campground                   | 15-Jun-07<br><br>Sunrise<br>Regional Health<br>Authority                   | PDWA issued for Cherrydale Golf and Campground due to poor bacteriological results           | 1    |      | Operational:<br><br>Quality: Suspected contamination   |
| Chilly's Pub and Grill (RM No. 183)              | 25-Jun-09<br><br>Sunrise<br>Regional Health<br>Authority                   | PDWA issued for Chilly's Pub and Grill (RM No. 183) due to the presence of coliform bacteria | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |
| Christopher Lake Housing Authority (Manor) [516] | 01-Jun-10<br><br>Prince Albert<br>Parkland<br>Regional Health<br>Authority | Christopher Lake Manor EBWO  |      | 1    | Operational: Contamination during construction, repair or operation<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                      | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|--|--|--|------|------|--|
| Churchill River Voyageur Lodge [15570]   | 24-Jun-11<br>Mamawetan Churchill River Regional Health Authority | EBWO Churchill River Voyager Lodge - upgraded from existing PDWA |      | 1    | Operational:<br><br>Quality: E.coli detected in drinking water system  |
| Churchill River Wilderness Camps [14673] | 24-Jun-11<br>Mamawetan Churchill River Regional Health Authority | EBWO for Churchill River Wilderness Camp due to E.coli           |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Clarke Lake Lodge [12634]                | 17-Jul-09<br>Mamawetan Churchill River Regional Health Authority | PDWA for Clarke Lake Lodge due to total coliforms                | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                     | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|---|--|--|------|------|--|
| Clearwater Lake Hotel - Clearwater Lake Regional Park   | 19-May-11<br>Heartland Regional Health Authority                 | PDWA Clearwater Lake Hotel- issue due to the absence of water sample submissions   | 1    |      | Operational: Does not meet reporting requirements<br><br>Quality: Suspected contamination  |
| Collins Camps & Outfittings Inc. - Cabin Lodges [14516] | 13-Jun-08<br>Mamawetan Churchill River Regional Health Authority | PDWA for Collins Camp & Outfitters Inc. (Besnard Lake) due to total coliforms      | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Collins Camps & Outfittings Inc. - Kitchen [21959]      | 13-Jun-09<br>Mamawetan Churchill River Regional Health Authority | PDWA for Collins Camps & Outfittings Inc. - Kitchen [21959] due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply               | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|-----------------------------------|--|---|------|------|--|
| Cowan Dam Campground [17238]      | 30-May-08<br>Mamawetan Churchill River Regional Health Authority | PDWA for Cowan Lake Campground due to total coliforms     | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Cree Lake Lodge 2009 Ltd. [15708] | 25-Jun-10<br>Mamawetan Churchill River Regional Health Authority | PDWA for Cree Lake Lodge 2009 Ltd. due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Cree River Lodge Inc. [15027]     | 17-Jul-09<br>Mamawetan Churchill River Regional Health Authority | EBWO for Cree River Lodge Inc. due to E.coli              |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply   | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments  |
|---|--|--|------|------|---|
| Crystal Lake Golf & Country Club Inc. Public Water Supply [13854] | 17-Jun-09<br>Sunrise Regional Health Authority                   | PDWA for Crystal Lake Golf & Country Club Inc Public Water Supply [13854] due to high nitrate count. | 1    |      | Operational:<br><br>Quality: Exceedance of MAC or drinking water standard   |
| Crystal Lodge Ltd. [15361]  | 28-Jun-10<br>Mamawetan Churchill River Regional Health Authority | EBWO - Crystal Lodge Ltd. Ispatamow Island, Cree Lake - existing PDWA amended to EBWO                |      | 1    | Operational:<br><br>Quality: Total coliforms detected in drinking water system  |
| D & D Camps [20860]   | 14-Jun-08<br>Mamawetan Churchill River Regional Health Authority | EBWO for D & D Camps due to E.coli - Duplex Cabin KS   |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply  | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|--|---|--|------|------|--|
| Danbury Community Well [13741]<br><br>Clayton, RM of #333, Facility #13741 | 22-Jun-07<br><br>Sunrise<br>Regional Health<br>Authority                      | PDWA for Danbury Community Well [13741] Clayton, RM of #333 due to poor bacteriological results. | 1    |      | Operational:<br><br>Quality: Exceedance of MAC or drinking water standard  |
| Deception Lake Lodge [15772]   | 04-Jun-07<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Deception Lake Lodge due to total coliforms   | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Deschambault Lake Resort [12334]   | 08-Jul-11<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Deschambault Lake Resort due to E.coli  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                 | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments  |
|-------------------------------------|---|--|------|------|---|
| Domremy Beach Resort Well [6482]    | 16-Apr-11<br><br>Saskatoon<br>Regional Health<br>Authority                    | Domremy Beach Resort Well [6482], PDWA, April 11, 2011. Michael Newell to follow up. | 1    |      | Operational: Does not meet minimum treatment/design requirements<br><br>Quality:                                    |
| Drinking Falls Lodge [14696]        | 24-Jun-10<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO issued for Drinking Falls Lodge [14696]   |      | 1    | Operational: No or inadequate disinfection at the treatment plant<br><br>Quality:                                   |
| Dyer Straits Campground Well [9872] | 07-May-12<br><br>No. 4 - Regina<br>Qu'Appelle<br>Regional Health<br>Authority | PDWA issued for Dyer Straits Campground Well, in RM 158                              | 1    |      | Operational: Undetermined source of contamination<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                  | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|--|---|--|------|------|--|
| Ebon Stables Concession - Cistern [17284]            | 16-Apr-10<br><br>Saskatoon<br>Regional Health<br>Authority                    | PDWA for Ebon Stables Concession - Cistern due to seasonal startup | 1    |      | Operational: Does not meet monitoring requirements<br><br>Quality: Suspected contamination   |
| Edam Community Recreation Centre Water Supply [1557] | 02-Mar-11<br><br>Prairie North<br>Regional Health<br>Authority                | PDWA - Edam Community Recreation Centre, Edam SK                   | 1    |      | Operational: Undetermined source of contamination<br><br>Quality: Total coliforms detected in drinking water system                    |
| Ena Lake Lodge [15024]                               | 04-Jul-07<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Ena Lake Lodge due to total coliforms                     | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                      | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments  |
|--|---|--|------|------|---|
| Eston Regional Park Water Supply [15595] | 21-May-10<br><br>Heartland<br>Regional Health<br>Authority                    | Eston Regional Park PDWA                           | 1    |      | Operational: Does not meet minimum treatment/design requirements<br><br>Quality: Suspected contamination                      |
| Foster River Camps [15159]               | 20-Jun-09<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Foster River Camps due to E.coli          |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| George Lake Camp Outfitting [15654]      | 10-Jun-06<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for George Lake Camp Outfitting due to E.coli |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply   | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|---|--|---|------|------|---|
| Glen Harbour Kids Camp Well [9881]                              | 26-May-10<br>No. 4 - Regina Qu'Appelle Regional Health Authority | PDWA Glen Harbour Kids Camp   | 1    |      | Operational: Undetermined source of contamination<br><br>Quality: Total coliforms detected in drinking water system |
| Good Spirit Bible Camp - Well [13694]<br><br>NE 08-29-05 W2     | 15-Jul-08<br>Sunrise Regional Health Authority                   | PDWA Good Spirit Bible Camp Well - issued due to lack of water sampling.                            | 1    |      | Operational: Does not meet monitoring requirements<br><br>Quality:  |
| Good Spirit Lake Provincial Park Recreation Hall - Well [13884] | 20-Mar-08<br>Sunrise Regional Health Authority                   | PDWA for Good Spirit Lake Provincial Park Recreation Hall - Well [13884] due to a lack of sampling. | 1    |      | Operational: Does not meet reporting requirements<br><br>Quality:   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                         | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|---|--|---|------|------|---|
| Grand Slam Lodge [15016]                    | 16-Jul-07<br>Mamawetan Churchill River Regional Health Authority | EBWO for Grand Slam Lodge due to detection of E. coli and total coliforms |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Green Acres Golf & Country Club Well [9882] | 27-Aug-10<br>No. 4 - Regina Qu'Appelle Regional Health Authority | PDWA - Green Acres Golf and Country Club                                  | 1    |      | Operational: Undetermined source of contamination<br><br>Quality: Total coliforms detected in drinking water system           |
| Green Lake Lodge [14556]                    | 02-Jul-09<br>Mamawetan Churchill River Regional Health Authority | EBWO for Green Lake Lodge due to E.coli                                   |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:13 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                      | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|--|---|--|------|------|--|
| Harvelle House Water Supply<br>[2811]    | 29-Nov-11<br><br>Prairie North<br>Regional Health<br>Authority                | Harvelle House PDWA  | 1    |      | Operational: Does not meet minimum treatment/design requirements<br><br>Quality: Total coliforms detected in drinking water system     |
| Haskins Bay Fly-in [12683]               | 17-Jun-11<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA issued on Haskins Bay Fly-in due to total coliforms           | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Hawkrock Wilderness Adventure<br>[15003] | 04-Jul-07<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Hawkrock Wilderness Adventure Ltd. due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                 | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments  |
|-------------------------------------|--|--|------|------|---|
| Hepburn Lake Lodge Ltd. [15597]     | 29-May-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Hepburn Lake Lodge Ltd. due to E.coli                               |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Hinchliffe RM - Well [13800]        | 30-Jul-09<br>Sunrise Regional Health Authority                   | PDWA issued for Hinchliffe RM - Well [13800] due to the presence of bacteria | 1    |      | Operational:<br><br>Quality: Exceedance of MAC or drinking water standard   |
| Indian Head Camp Adventures [15245] | 30-Jul-10<br>Mamawetan Churchill River Regional Health Authority | EBWO for Indian Head Camp Adventures due to E.coli                           |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply  | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|--|--|---|------|------|---|
| Jan Lake Convenience Store [15974]                                   | 02-Sep-11<br>Mamawetan Churchill River Regional Health Authority | Jan Lake Convenience Store  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system       |
| Jims Camps [15228]   | 29-May-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Jim's Camp due to E.coli   |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system       |
| Jims Meats - Water Supply [14858]<br><br>Jims Meats - food processor | 27-Jan-12<br>Heartland Regional Health Authority                 | PDWA Jim's Meats - SW 28-38-24W3M in the Rural Municipality of Grass Lake # 381 | 1    |      | Operational: No or inadequate disinfection at the treatment plant<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply           | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|-------------------------------|--|---|------|------|---|
| Johnson River Camp [23361]    | 07-Jun-10<br>Mamawetan Churchill River Regional Health Authority | EBWO for Johnson River Camp due to E.coli     |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Jug Bay Sport Fishing [21119] | 30-Jul-10<br>Mamawetan Churchill River Regional Health Authority | EBWO for Jug Bay Sport Fishing due to E.coli  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Kamkota Lodge [12726]         | 31-May-08<br>Mamawetan Churchill River Regional Health Authority | EBWO for Kamkota Lodge Cabin #2 due to E.coli |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                       | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|---|---|--|------|------|--|
| Kandahar Waterworks Well<br>[6631]        | 29-Apr-10<br><br>Saskatoon<br>Regional Health<br>Authority                    | PDWA - Kandahar Waterworks due to total coliforms  | 1    |      | Operational: Does not meet minimum treatment/design requirements<br><br>Quality: Total coliforms detected in drinking water system     |
| Keefe Lake Camp [15208]                   | 14-Jul-11<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | Keefe Lake Camps   | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Kennedy Friendship Centre Well<br>[10586] | 14-May-12<br><br>Sun Country<br>Regional Health<br>Authority                  | PDWA issued for Kennedy Friendship Centre, Kennedy Sk. well due to presence of coliform bacteria | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                 | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|-------------------------------------|--|---|------|------|---|
| Kennedy Well [8421]                 | 24-Jun-10<br>Sun Country Regional Health Authority               | EBWO issued for Kennedy Well in RM 93             |      | 1    | Operational:<br><br>Quality: E.coli detected in drinking water system   |
| Kingfisher Lodge [15598]            | 11-Jun-11<br>Mamawetan Churchill River Regional Health Authority | PDWA issued on Kingfisher Lodge                   | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system  |
| La Fleur Outdoor Adventures [14681] | 14-Jul-09<br>Mamawetan Churchill River Regional Health Authority | EBWO for Lafleur Outdoor Adventures due to E.coli |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply   | Date Issued and<br>Regional Health<br>Authority          | Title   | PDWA | EBWO | Comments   |
|---|--|---|------|------|--|
| Lady Lake Hamlet - Well [13799]<br><br>RM of Preeceville #334, SE 27-35-5-W2M | 30-Jul-09<br><br>Sunrise<br>Regional Health<br>Authority | PDWA for Lady Lake Hamlet - Well [13799] due to high nitrate count.                             | 1    |      | Operational:<br><br>Quality: Exceedance of MAC or drinking water standard      |
| Lady Lake Regional Park - Well [13511]<br><br>RM of Preeceville #334          | 15-Jun-09<br><br>Sunrise<br>Regional Health<br>Authority | PDWA for Lady Lake Regional Park - Well RM of Preeceville #333 due to the presence of bacteria. | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system |
| Lady Lake RM - Well [13803]<br><br>Preeceville, RM of (NW 23-35-5-W2nd)       | 28-Jun-07<br><br>Sunrise<br>Regional Health<br>Authority | EBWO for Lady Lake RM - Well [13803] Preeceville due to presence of total coliform and E.Coli.  |      | 1    | Operational:<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply          | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|------------------------------|--|---|------|------|---|
| Lake Athabasca Lodge [15383] | 26-Jun-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Lake Athabasca Lodge due to E.coli                               |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Langenburg, RM of #181       | 11-Jun-09<br>Sunrise Regional Health Authority                   | PDWA for Langenburg, RM of #181 due to the presence of coliform bacteria. | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system  |
| LEOVILLE WATERWORKS          | 11-May-12<br>Prince Albert Parkland Regional Health Authority    | Emergency Boil Water Order: Leoville SK                                   |      | 1    | Operational:<br><br>Quality: E.coli detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                    | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|--|--|---|------|------|--|
| Lindberghs Reindeer Lake Lodge [15132] | 16-Jul-07<br>Mamawetan Churchill River Regional Health Authority | PDWA for Lindbergh's Reindeer Lake Lodge due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Lloyd Lake Lodge Ltd. [15684]          | 16-Jun-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Lloyd Lake Lodge Ltd. - N 57.33715 due to E.coli       |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Lloyd Lake Lodge Ltd. [15684]          | 15-Jun-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Lloyd Lake Lodge Ltd. due to E.coli                    |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply              | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments  |
|----------------------------------|--|--|------|------|---|
| Lone Wolf Camps [15903]          | 25-Jun-07<br>Mamawetan Churchill River Regional Health Authority | EBWO for Lone Wolf Camps due to E.coli       |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Luseland Campground Well [23333] | 02-Jul-10<br>Heartland Regional Health Authority                 | PDWA - Luseland Campground                   | 1    |      | Operational: Undetermined source of contamination<br><br>Quality: Total coliforms detected in drinking water system           |
| MacPherson Lake Lodge [14986]    | 29-May-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for MacPherson Lake Lodge due to E.coli |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply  | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|--|--|---|------|------|--|
| Manewan Enterprises Ltd. - Marchel Lake [15730]                                      | 25-Jun-07<br>Mamawetan Churchill River Regional Health Authority | PDWA for Manewan Enterprises Ltd. - Marchel Lake due to total coliforms                           | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Manewan Enterprises Ltd. - Nemei Lake [15719]  | 24-Jun-11<br>Mamawetan Churchill River Regional Health Authority | PDWA issued on Manewan Enterprises Ltd. - Nemei Lake - total coliforms detected in drinking water | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Meadows Edge Bed and Breakfast [21301]<br><br>RM of Preeceville #334, NE 11-35-6 W2M | 30-Jul-09<br>Sunrise Regional Health Authority                   | PDWA for Meadows Edge Bed and Breakfast [21301] RM of Preeceville due to the presence of bacteria | 1    |      | Operational:<br><br>Quality: Exceedance of MAC or drinking water standard  |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply       | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|---------------------------|--|--|------|------|--|
| Milton Lake Lodge [15324] | 26-Jun-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Milton Lake Lodge due to E.coli   |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Minor Bay Lodge [15010]   | 22-Jun-10<br>Mamawetan Churchill River Regional Health Authority | PDWA for Minor Bay Lodge & Outpost Ltd - Spencer Lake Outpost due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Missy's Restaurant [7277] | 11-Aug-11<br>Saskatoon Regional Health Authority                 | PDWA, Missy's Restaurant [7277]. Repeat sample with TC. Follow up done by DD.        | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply               | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|-----------------------------------|--|---|------|------|--|
| Moonlight Bay Store Water [23303] | 09-Mar-11<br>Prairie North Regional Health Authority             | Moonlight Bay Store PDWA                          | 1    |      | Operational: Undetermined source of contamination<br><br>Quality: Total coliforms detected in drinking water system  |
| Morning Lake Outfitters [16118]   | 14-Jun-07<br>Mamawetan Churchill River Regional Health Authority | EBWO for Morning Lake Outfitters due to E.coli    |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system  |
| Navau Park Water Supply [8667]    | 23-Jun-11<br>Sun Country Regional Health Authority               | EBWO issued to Navau Trailer Park due to flooding |      | 1    | Operational: Treatment unable to cope with significant deterioration in source water quality<br><br>Quality: Significant deterioration of source water quality due to environmental conditions |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply               | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|-----------------------------------|--|---|------|------|--|
| Norseman Outfitters [17572]       | 21-Apr-11<br>Prince Albert Parkland Regional Health Authority    | Norseman Outfitting EBWO due to E.coli                    |      | 1    | Operational: Does not meet reporting requirements<br><br>Quality: E.coli detected in drinking water system                             |
| Northern Echo Lodge [13963]       | 26-Jun-06<br>Mamawetan Churchill River Regional Health Authority | EBWO for Northern Echo Lodge due to E.coli                |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Northern Reflection Lodge [15265] | 22-Jun-10<br>Mamawetan Churchill River Regional Health Authority | PDWA for Northern Reflection Lodge due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                      | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|--|--|---|------|------|--|
| OBriens Fly-in Careen Lake Lodge [16081] | 13-Jun-08<br>Mamawetan Churchill River Regional Health Authority | PDWA for O'Brien's Fly-in Careen Lake Lodge due to total coliforms          | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Osin Community Well [13767]              | 14-Sep-07<br>Sunrise Regional Health Authority                   | PDWA issued for Osin Community Well [13767] due to the presence of coliform | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |
| Paull River Wilderness Camp [12523]      | 17-Jun-09<br>Mamawetan Churchill River Regional Health Authority | EBWO for Paull River Wilderness Camps due to E.coli                         |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                 | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|-------------------------------------|--|---|------|------|--|
| Pawistik Lodge Inc. [12223]         | 04-Jun-02<br>Mamawetan Churchill River Regional Health Authority | EBWO issued for Pawistik Lodge Inc. [12223]                 |      | 1    | Operational: No or inadequate disinfection at the treatment plant<br><br>Quality:  |
| Phantom Lake Golf Club Inc. [12498] | 01-Aug-10<br>Mamawetan Churchill River Regional Health Authority | PDWA Phantom Lake Golf Course MCRRHA                        | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Phantom Lake Golf Club Inc. [12498] | 01-Aug-10<br>Mamawetan Churchill River Regional Health Authority | PDWA for Phantom Lake Golf Club Inc. due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                    | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|--|--|--|------|------|--|
| Phil Foster Wilderness Fishing [15819] | 25-Jun-07<br>Mamawetan Churchill River Regional Health Authority | PDWA for Phil Foster Wilderness Fishing due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Pickerel Bay Cabins Ltd. [15268]       | 11-Jun-10<br>Mamawetan Churchill River Regional Health Authority | EBWO for Pickerel Bay Cabins Ltd. due to E.coli                |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Pilots Lodge [17110]                   | 01-Jul-07<br>Mamawetan Churchill River Regional Health Authority | EBWO for Pilot's Lodge due to E.coli                           |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                       | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|---|---|--|------|------|--|
| Pine Point Lodge & Outpost -<br>Athapapuskow Lake [14162] | 08-Jun-07<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Pine Point Lodge & Outpost due to<br>total coliforms        | 1    |      | Operational: Inadequate disinfection residual in<br>distribution system<br><br>Quality: Total coliforms detected in drinking water<br>system |
| Pipestone Lake Fishing Lodge<br>Inc. [12506]              | 25-Jun-07<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Pipestone Lake Fishing Lodge Inc.<br>due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in<br>distribution system<br><br>Quality: Total coliforms detected in drinking water<br>system |
| Pointer Lake Lodge Ltd. [12548]                           | 04-Jun-10<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Pointer Lake Lodge due to total<br>coliforms                | 1    |      | Operational: Inadequate disinfection residual in<br>distribution system<br><br>Quality: Total coliforms detected in drinking water<br>system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                             | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|---|--|---|------|------|--|
| Prairie Lake Regional Park Water Supply [23306] | 21-May-10<br>Heartland Regional Health Authority                 | Prairie Lake Regional Park Water System PDWA due to lack of treatment | 1    |      | Operational: Does not meet minimum treatment/design requirements<br><br>Quality: Suspected contamination                               |
| Prill Lake Lodge [15899]                        | 13-Jun-08<br>Mamawetan Churchill River Regional Health Authority | PDWA for Prill Lake Lodge due to total coliforms                      | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Prince Public Well [11268]                      | 14-May-04<br>Prairie North Regional Health Authority             | Prince Public Well, Bacterial Contamination (EBWO)                    |      | 1    | Operational: Does not meet minimum treatment/design requirements<br><br>Quality: Total coliforms detected in drinking water system     |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                        | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|--|--|---|------|------|--|
| R & R Wilderness Lodge [14036]             | 05-Jun-09<br>Mamawetan Churchill River Regional Health Authority | PDWA for R & R Wilderness Lodge due to total coliforms                | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| R.M. #95 - Well 3 Handsworth (East) [8655] | 05-Apr-12<br>Sun Country Regional Health Authority               | PDWA issued for RM # 95 East Handsworth well due to coliform bacteria | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |
| R.M. #96 - Well 4 (Hand Pump) [15338]      | 29-Apr-11<br>Sun Country Regional Health Authority               | PDWA issued for RM 96 Well #4 due to detection of total coliform      | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                           | Date Issued and Regional Health Authority          | Title   | PDWA | EBWO | Comments  |
|---|--|---|------|------|---|
| Readlyn Water Co-operative [16221]            | 30-Jul-09<br>Five Hills Regional Health Authority  | Readlyn Water Co-op PDWA  | 1    |      | Operational: Does not meet minimum treatment/design requirements<br><br>Quality: Suspected contamination                              |
| Riverside Hotel - Water [8732]                | 21-Dec-09<br>Sun Country Regional Health Authority | PDWA for Riverside Hotel in Gainsborough upgraded to EBWO due to presence of E coli |      | 1    | Operational: Does not meet minimum treatment/design requirements<br><br>Quality: E.coli detected in drinking water system             |
| RM 288 Fiske John Smith Memorial Well [15313] | 11-May-12<br>Heartland Regional Health Authority   | Precautionary Drinking Water Advisory Hamlet of Fiske John Smith Well               | 1    |      | Operational: Contamination during construction, repair or operation<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply   | Date Issued and Regional Health Authority        | Title  | PDWA | EBWO | Comments   |
|---|--|--|------|------|--|
| RM 340 Community Well #1 [6139]                                       | 28-Aug-09<br>Saskatoon Regional Health Authority | PDWA issued for RM 340 Community Well #1 [6139] (Wolverine) due to total coliforms           | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system |
| Rural Municipality of Buchanan No. 304 - Well (NE 33-33-5 W2) [13624] | 16-Jun-10<br>Sunrise Regional Health Authority   | EBWO for Rural Municipality of Buchanan No. 304 - Well (NE 33-33-5 W2) [13624] due to E.coli |      | 1    | Operational:<br><br>Quality: E.coli detected in drinking water system          |
| Rural Municipality of Buchanan No. 304 - Well (SE 23-32-4-W2) [13621] | 25-Mar-11<br>Sunrise Regional Health Authority   | PDWA for R.M. of Buchanan Well No. 4 (SE-23-32-4 - Est.#13621) replaces EBWO of May 13, 2010 | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply  | Date Issued and<br>Regional Health<br>Authority          | Title   | PDWA | EBWO | Comments   |
|--|--|---|------|------|--|
| Rural Municipality of Saltcoats<br>No. 213 - Public Well [13403]<br><br>Well #1, NW 13-24-3-W2nd | 10-Oct-07<br><br>Sunrise<br>Regional Health<br>Authority | PDWA for RM of Saltcoats No. 213 - Public Well #1 [13403] due to the presence of coliform bacteria. | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system |
| Rural Municipality of Sliding Hills<br>No. 273 - Well No. 1 [13625]                              | 07-Oct-10<br><br>Sunrise<br>Regional Health<br>Authority | EBWO issued to R.M.#273 - Sliding Hills Community Well#1 (Donwell) due to detection of E. coli      |      | 1    | Operational:<br><br>Quality: E.coli detected in drinking water system          |
| Rural Municipality of Sliding Hills<br>No. 273 - Well No. 4 (Petriw Well)<br>[13628]             | 13-Jul-07<br><br>Sunrise<br>Regional Health<br>Authority | PDWA for RM of Sliding Hills No. 273 - Well No. 4 (Petriw Well) [13628] due to high nitrate levels  | 1    |      | Operational:<br><br>Quality: Exceedance of MAC or drinking water standard      |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                       | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments  |
|---|--|--|------|------|---|
| Sandyridge Gas and Grocery - Well [14833] | 21-Oct-11<br>Saskatoon Regional Health Authority                 | PDWA Sandy Ridge Gas and Grocery, Follow up by DL Oct 21, 2011.                  | 1    |      | Operational: No or inadequate disinfection at the treatment plant<br><br>Quality: Total coliforms detected in drinking water system |
| Saskairie Outdoor Centre Well [8662]      | 23-Sep-11<br>Sun Country Regional Health Authority               | PDWA issued for Saskairie Outdoor Centre Well due to presence of total coliforms | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system  |
| Scott Lake Lodge Ltd. [15144]             | 13-Jul-10<br>Mamawetan Churchill River Regional Health Authority | EBWO for Scott Lake Lodge Ltd. due to E. coli                                    |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system       |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                 | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|---|--|---|------|------|--|
| Shannon Lake Campground Cistern [14534]             | 16-Apr-10<br>Saskatoon Regional Health Authority                 | PDWA for Shannon Lake Campground Cistern due to total coliforms                     | 1    |      | Operational: Does not meet monitoring requirements<br><br>Quality: Suspected contamination   |
| Silence of the North Hunting & Fishing Inc. [12159] | 27-Jul-11<br>Mamawetan Churchill River Regional Health Authority | Silence of the North Hunting & Fishing Inc.   | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Slim's Cabins Ltd. - Golden Lake                    | 20-Jun-11<br>Mamawetan Churchill River Regional Health Authority | EBWO for Slim's Cabins Ltd. - Golden Lake due to E.Coli and inadequate disinfection |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                         | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments  |
|---|---|--|------|------|---|
| Slim's Cabins Ltd. - Laurie Lake<br>[13982] | 27-Jun-09<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Slim's Cabins - Laurie Lake due to E.coli                         |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Slim's Cabins Ltd. -Scotties Beach [13972]  | 25-Jun-07<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Russell's Churchill River Camp Ltd - Scotties Beach due to E.coli |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |
| Slims Cabins - Kipahigan Lake<br>[13956]    | 10-Jun-11<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Slim's Cabins - Kipahigan Lake due to E.coli                      |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                               | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|---|--|---|------|------|--|
| Slims Cabins Ltd. - Tomahawk Lake Outpost [12418] | 20-Jun-11<br>Mamawetan Churchill River Regional Health Authority | EBWO for Slim's Cabins Ltd. - E. coli detected in Tomahawk Lake Outpost drinking water system |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Slims Cabins. - Kamuchawie Lake [13978]           | 20-Jun-11<br>Mamawetan Churchill River Regional Health Authority | PDWA Issued at Slim's Cabins Ltd. - Kamuchawie Lake - due to detection of total coliforms     | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| South Bay Outfitters Ltd. [15672]                 | 09-Aug-10<br>Mamawetan Churchill River Regional Health Authority | EBWO issued for South Bay Outfitters Ltd. [15672] due to E.coli                               |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply           | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|-------------------------------|--|--|------|------|--|
| Spring Bay Lodge [15127]      | 13-Jul-10<br>Mamawetan Churchill River Regional Health Authority | PDWA for Lakers Unlimited Inc. - Spring Bay Lodge due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system                         |
| Stornoway Public Well [13647] | 30-Jul-10<br>Sunrise Regional Health Authority                   | PDWA - Stornoway Public Well   | 1    |      | Operational: Treatment unable to cope with significant deterioration in source water quality<br><br>Quality: Total coliforms detected in drinking water system |
| Sunshine Fairways [20761]     | 12-Aug-09<br>Prince Albert Parkland Regional Health Authority    | PDWA for Sunshine Fairways [20761]                                       | 1    |      | Operational: Does not meet minimum treatment/design requirements<br><br>Quality:   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                   | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|---------------------------------------|---|--|------|------|--|
| Swedes Bed N Breakfast - Well [13478] | 20-Jun-08<br><br>Sunrise<br>Regional Health<br>Authority                      | PDWA: Swedes Bed N Breakfast - Well 13478 due to total coliform bacteria & lack of water sampling. | 1    |      | Operational: Does not meet monitoring requirements<br><br>Quality: Total coliforms detected in drinking water system                   |
| T & D Amisk Cabins Inc. [12136]       | 01-Aug-10<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for T & D Amisk Cabins Inc. due to total coliforms  | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Tanks Country Meats - Well [13825]    | 14-Dec-07<br><br>Sunrise<br>Regional Health<br>Authority                      | PDWA issued to Tanks Country Meats - Well [13825] due to the presence of coliform bacteria         | 1    |      | Operational:<br><br>Quality: Total coliforms detected in drinking water system   |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|--|--|---|------|------|--|
| Tate Island Lodge [14080]                          | 19-Jul-08<br>Mamawetan Churchill River Regional Health Authority | EBWO for Tate Island Lodge due to E.coli  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| The Cranky Chef - Well [24725]<br>The Gateway Esso | 14-Feb-12<br>Cypress Regional Health Authority                   | PDWA Issued to Cranky Chef Well and Gateway Esso, Maple Creek, Saskatchewan, #1 Highway | 1    |      | Operational: Contamination during construction, repair or operation<br><br>Quality: Suspected contamination                            |
| The New Canoe Lake West Resort 1987 [16087]        | 11-Sep-10<br>Mamawetan Churchill River Regional Health Authority | PDWA for The New Canoe Lake West Resort 1987 due to total coliforms                     | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                  | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments   |
|--|--|---|------|------|--|
| Theodore Motor Hotel - Well [13652]                  | 07-Mar-08<br>Sunrise Regional Health Authority                   | PDWA for Theodore Motor Hotel - Well [13652] inadequate number of water samples | 1    |      | Operational: Does not meet monitoring requirements<br><br>Quality:   |
| Thompson's Camps - Daly Lake Outpost [15576]         | 16-Jun-10<br>Mamawetan Churchill River Regional Health Authority | EBWO for Thompson's Camp - Daly Lake Outpost due to E.coli                      |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Thompson's Camps - Upper Foster Lake Outpost [16540] | 20-Jun-09<br>Mamawetan Churchill River Regional Health Authority | PDWA for Thompson's Camps - Upper Foster Lake Outpost due to total coliforms    | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                    | Date Issued and<br>Regional Health<br>Authority                               | Title  | PDWA | EBWO | Comments   |
|--|---|--|------|------|--|
| Thunder Mountain Outfitting<br>[21930] | 06-Jun-09<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Thunder Mountain Outfitting due to E.coli         |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |
| Top of the Rock Adventures<br>[23552]  | 17-Jun-10<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | PDWA for Top of the Rock Adventures due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Tower Lodge Outfitting [16108]         | 14-Jul-09<br><br>Mamawetan<br>Churchill River<br>Regional Health<br>Authority | EBWO for Tower Lodge Outfitting due to E.coli              |      | 1    | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: E.coli detected in drinking water system          |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply        | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|----------------------------|--|--|------|------|--|
| Triveet Lake Lodge [14975] | 21-Jun-08<br>Mamawetan Churchill River Regional Health Authority | PDWA for Triveet Lake Lodge due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Trout Lake Camp [15276]    | 17-Aug-07<br>Mamawetan Churchill River Regional Health Authority | PDWA for Trout Lake Camp due to total coliforms    | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| True North Lodge [17361]   | 20-Jun-08<br>Mamawetan Churchill River Regional Health Authority | EBWO issued for True North Lodge [17361]           |      | 1    | Operational:<br><br>Quality: E.coli detected in drinking water system  |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                         | Date Issued and Regional Health Authority                        | Title   | PDWA | EBWO | Comments  |
|---|--|---|------|------|---|
| Tuffnell Recreation Centre - Well [13428]   | 18-Oct-07<br>Sunrise Regional Health Authority                   | EBWO for Tuffnell Recreation Centre - Well [13428] due to the presence of total coliform and E.Coli |      | 1    | Operational:<br>Quality: E.coli detected in drinking water system   |
| Tuxford Rural Water Supply Pipeline [17308] | 06-Jul-09<br>Five Hills Regional Health Authority                | Tuxford Rural Water Pipeline PDWA   | 1    |      | Operational: Does not meet monitoring requirements<br>Quality:  |
| Twin Bay Resort Ltd. [16112]                | 02-Sep-11<br>Mamawetan Churchill River Regional Health Authority | Twin Bay Resort Ltd.  |      | 1    | Operational: Inadequate disinfection residual in distribution system<br>Quality: E.coli detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply              | Date Issued and Regional Health Authority                        | Title  | PDWA | EBWO | Comments   |
|----------------------------------|--|--|------|------|--|
| Ubiquity Lake Outfitters [15879] | 25-Jun-07<br>Mamawetan Churchill River Regional Health Authority | PDWA for Ubiquity Lake Outfitters due to total coliforms | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |
| Verwood Water Inc. [16364]       | 05-Aug-08<br>Five Hills Regional Health Authority                | Verwood Water Inc PDWA                                   | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Suspected contamination                           |
| VJ's Fishing Lodge Ltd. [12608]  | 08-Jun-07<br>Mamawetan Churchill River Regional Health Authority | PDWA for V.J. Fishing Camp due to total coliforms        | 1    |      | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Total coliforms detected in drinking water system |

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 18 May 2012 15:22:14 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply                                     | Date Issued and<br>Regional Health<br>Authority             | Title   | PDWA       | EBWO      | Comments  |
|---|---|---|------------|-----------|---|
| Wood Mountain Regional Park Well - Pool [11262]         | 18-Jun-10<br><br>Five Hills<br>Regional Health<br>Authority | Wood Mountain Regional Park PDWA                        | 1          |           | Operational:<br><br>Quality: Total coliforms detected in drinking water system  |
| Wood Mountain Regional Park Well - Showers [11263]      | 08-Jun-11<br><br>Five Hills<br>Regional Health<br>Authority | PDWA Issued for Wood Mountain Regional Park Shower Well | 1          |           | Operational: Inadequate disinfection residual in distribution system<br><br>Quality: Unacceptable turbidity or particle counts in treated water |
| York Lake Golf & Country Club Inc. - Well No. 2 [16730] | 17-May-11<br><br>Sunrise<br>Regional Health<br>Authority    | York Lake Golf & Country Club EBWO remains in effect.   | 1          |           | Operational: Treatment / distribution equipment failure or damage<br><br>Quality: Suspected contamination                                       |
| <b>Totals:</b>  |   |   | <b>100</b> | <b>65</b> |   |
| <b>Advisories/Orders Currently in Effect:</b>           |   |   | <b>165</b> |           |   |